

SE-108759M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

\sim D $^{-1}$	гсст	CEDI		A TE
CD I	IEJI	CERI	IIFIL	AIE

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd. No.1 Chint Road, Chint Industrial Zone North Baixiang, Yueging, Zhejiang Province, P.R. China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

☐ Additional Information on page 2

Ratings and principal characteristics

See page 2

Trademark / Brand (if any)

Model / Type Ref.

CHNT

Customer's Testing Facility (CTF) Stage used

NXB-63

Additional information (if necessary may also be reported on page 2)

□ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

220500316SHA-001, 220500316SHA-001A1, 220500316SHA-001 A2

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB Torshamnsgatan 43 **Box 1103** SE-164 22 Kista, Sweden

Date: 22 July, 2024

Signature:

intertek

Håkan Triksson

Håkan Eriksson

1/2 **EMG**



SE-108759M2

Rating and principal characteristics

 $\begin{array}{l} U_{n} = AC220V/230V/240V~(1P,~1P+N,~2P) \\ U_{n} = AC380V/400V/415V~(2P,~3P,~3P+N,~4P) \\ I_{n} = 1,~2,~3,~4,~6,~10,~16,~20,~25,~32,~40,~50,~63A \\ I_{cs} = I_{cn} = 6000A~(1P,~2P,~1P+N,~3P,~3P+N,~4P) \\ I_{cs} = 7500A,~I_{cn} = 10000A~(2P,~AC220V/230V/240V) \\ B_{-},~C_{-} \&~D_{-}type,~with~switched~neutral \\ \end{array}$

Additional information

The requirements for EN 60898-1:2019, BS EN 60898-1:2019 and AS/NZS 60898.1:2024 have also been checked.

This certificate replaces previously issued certificate ref. No. SE-108759M1 dated 29 November 2022, due to adding an alternative enclosure of grey color and updating standard from AS/NZS 60898.1:2004 to AS/NZS 60898.1:2024.

Date: 22 July, 2024 Signature: Hakan Tiksson

2/2 EMG